



Government of Andhra Pradesh
WATER TESTING LABORATORY - NELLORE

Report on Chemical Analysis of Drinking Water
General - Physical & chemical Parameters

Sample Receiver Name : Tiny Tots English Medium High School (CBSE Campus)Sr.No128/2,128/3,Sulluru,sullurupeta,Tirupathi,Andhra pradesh - 524121

Details of the sample : Block - A

Sample receiving date : 31.12.2024

Date of report issue: 31.12.2024

S.no	Physcio-Chemical Parameters	Units	As per Drinking water specification IS 10500 : 2012			
			Test Methods	Acceptable Limit	Permissible Limit	sample result
1	Colour	Hazen units	IS 3025 Part 4	5	15	1
2	Odour	-	IS 3025 Part 5	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	Ref to part of IS 3025 part 10	1.0	5.0	0.5
4	pH at 25 °c	-	Ref to part of IS 3025 part 11	6.5-8.5	No relaxation	6.58
5	Conductivity at 25 °c	µS/cm	-	-	-	65
6	Total Dissolved Solids	mg/lit	Ref to part of IS 3025 part 16	500	2000	42
7	Total Alkalinity as CaCO ₃	mg/lit	Ref to part of IS 3025 part 23	200	600	20
8	Total Hardness as CaCO ₃	mg/lit	Ref to part of IS 3025 part 21	200	600	20
9	Calcium as Ca ⁺⁺	mg/lit	Ref to part of IS 3025 part 40	75	200	5
10	Magnesium as Mg ⁺⁺	mg/lit	Ref to part of IS 3025 part 46	30	100	2
11	Chloride as Cl ⁻	mg/lit	Ref to part of IS 3025 part 32	250	1000	17
12	Flouride as F ⁻	mg/lit	Ref to part of IS 3025 part 60	1.0	1.5	0.08
13	Nitrate as NO ₃ ⁻	mg/lit	Ref to part of IS 3025 part 34	45	No relaxation	1.6
14	Sulphate as SO ₄ ⁻	mg/lit	Ref to part of IS 3025 part 24	200	400	6
15	Total Iron as Fe	mg/lit	Ref to part of IS 3025 part 53	1.0	No relaxation	0.07

Remarks : Suitable for Drinking

- Note:** 1.Sample collection is not responcible for Laboratory personals.
2.The above said results are related only to the sample tested.



Analyzed by
Water Analyst



Government of Andhra Pradesh
WATER TESTING LABORATORY - NELLORE

Report on Chemical Analysis of Drinking Water
General - Physical & chemical Parameters

Sample Receiver Name : Tiny Tots English Medium High School (CBSE Campus)Sr.No128/2,128/3,Sulluru,sullurupeta,Tirupathi,Andhra pradesh - 524121

Details of the sample : Block - B


Sample receiving date : 31.12.2024

Date of report issue: 31.12.2024

S.no	Physcio-Chemical Parameters	Units	As per Drinking water specification IS 10500 : 2012			
			Test Methods	Acceptable Limit	Permissible Limit	sample result
1	Colour	Hazen units	IS 3025 Part 4	5	15	1
2	Odour	-	IS 3025 Part 5	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	Ref to part of IS 3025 part 10	1.0	5.0	0.8
4	pH at 25 °c	-	Ref to part of IS 3025 part 11	6.5-8.5	No relaxation	6.89
5	Conductivity at 25 °c	µS/cm	-	-	-	384
6	Total Dissolved Solids	mg/lit	Ref to part of IS 3025 part 16	500	2000	250
7	Total Alkalinity as CaCO ₃	mg/lit	Ref to part of IS 3025 part 23	200	600	132
8	Total Hardness as CaCO ₃	mg/lit	Ref to part of IS 3025 part 21	200	600	128
9	Calcium as Ca ⁺⁺	mg/lit	Ref to part of IS 3025 part 40	75	200	29
10	Magnesium as Mg ⁺⁺	mg/lit	Ref to part of IS 3025 part 46	30	100	14
11	Chloride as Cl ⁻	mg/lit	Ref to part of IS 3025 part 32	250	1000	91
12	Flouride as F ⁻	mg/lit	Ref to part of IS 3025 part 60	1.0	1.5	0.12
13	Nitrate as NO ₃ ⁻	mg/lit	Ref to part of IS 3025 part 34	45	No relaxation	3.9
14	Sulphate as SO ₄ ⁻	mg/lit	Ref to part of IS 3025 part 24	200	400	2.1
15	Total Iron as Fe	mg/lit	Ref to part of IS 3025 part 53	1.0	No relaxation	0.12

Remarks : Suitable for Drinking

- Note:** 1. Sample collection is not responsible for Laboratory personnel.
2. The above said results are related only to the sample tested.



Analyzed by
Water Analyst



Government of Andhra Pradesh
WATER TESTING LABORATORY - NELLORE

Report on Chemical Analysis of Drinking Water
General - Physical & chemical Parameters

Sample Receiver Name : Tiny Tots English Medium High School (CBSE Campus)Sr.No128/2,128/3,Sulluru,sullurupeta,Tirupathi,Andhra pradesh - 524121

Details of the sample : Block - C

Sample receiving date : 31.12.2024

Date of report issue: 31.12.2024

S.no	Physcio-Chemical Parameters	Units	As per Drinking water specification IS 10500 : 2012			
			Test Methods	Acceptable Limit	Permissible Limit	sample result
1	Colour	Hazen units	IS 3025 Part 4	5	15	1
2	Odour	-	IS 3025 Part 5	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	Ref to part of IS 3025 part 10	1.0	5.0	1.0
4	pH at 25 °c	-	Ref to part of IS 3025 part 11	6.5-8.5	No relaxation	7.00
5	Conductivity at 25 °c	µS/cm	-	-	-	427
6	Total Dissolved Solids	mg/lit	Ref to part of IS 3025 part 16	500	2000	278
7	Total Alkalinity as CaCO ₃	mg/lit	Ref to part of IS 3025 part 23	200	600	140
8	Total Hardness as CaCO ₃	mg/lit	Ref to part of IS 3025 part 21	200	600	132
9	Calcium as Ca ⁺⁺	mg/lit	Ref to part of IS 3025 part 40	75	200	30
10	Magnesium as Mg ⁺⁺	mg/lit	Ref to part of IS 3025 part 46	30	100	13
11	Chloride as Cl ⁻	mg/lit	Ref to part of IS 3025 part 32	250	1000	111
12	Flouride as F ⁻	mg/lit	Ref to part of IS 3025 part 60	1.0	1.5	0.16
13	Nitrate as NO ₃ ⁻	mg/lit	Ref to part of IS 3025 part 34	45	No relaxation	2.3
14	Sulphate as SO ₄ ⁻	mg/lit	Ref to part of IS 3025 part 24	200	400	28
15	Total Iron as Fe	mg/lit	Ref to part of IS 3025 part 53	1.0	No relaxation	0.11

Remarks : Suitable for Drinking

- Note:** 1.Sample collection is not responsible for Laboratory personnel.
2.The above said results are related only to the sample tested.



Analyzed by
Water Analyst



Government of Andhra Pradesh
WATER TESTING LABORATORY - NELLORE

Payment Receipt

Receipt no : 170

Date : 31.12.2024

Amount Received : Rs : 3000 /- (Three thousands rupees only)

Paid by Cash / Cheque/ Demand Draft/ other mode : Cash

**Received from : Tiny Tots English Medium High School (CBSE
Campus)Sr.No128/2,128/3,Sulluru,sullurupeta,Tirupathi,Andhra pradesh - 524121**

Towards the testing charges of Water (Drinking) Samples : 3 nos

Amount Received By : Water Testing Lab Nellore



Signature of lab Staff.

ROC:11/2018/F1

Municipal office,
Sullurpet .Dated:06.11.2020

NO OBJECTION CERTIFICATE

Sub: Municipal commissioner of Sullurpet – Public Health Section – No Objection certificate to run or open TINY TOTS ENGLISH MEDIUM HIGH SCHOOL situated at Sullurpet- NO - OBJECTION CERTIFICATE – issued

Ref: 1) Application of Sri. V. DHANUNJAY REDDY, correspondent, TINY TOTS ENGLISH MEDIUM HIGH SCHOOL situated at Sullurpet- Dated
2) Sanitary Inspection Remarks Receive on

This is to certify that there is NO OBJECTION from public Health points of view to run TINY TOTS ENGLISH MEDIUM HIGH SCHOOL situated at Govt. Hospital Road, Sullurpet subject to the following conditions


1. It should not be source of nuisance to the others.
2. The premises should be kept clean and neat.
3. Urinals and Latrine should be cleaned every day
4. The staff working in the unit should not posses any type communicable diseases.
5. If any complaint received from public this NO OBJECTION CERTIFICATE will be cancelled Without any further notice and without any prior intimation.
6. The Drinking water supplied to the staff/ students should be wholesome and chlorinated.
7. The commissioner or Health Officer or any officer authorized by the commissioner can inspect the Unit at any time as and when required.



COMMISSIONER
SULLURPET MUNICIPALITY

To

Correspondent

TINY TOTS ENGLISH MEDIUM HIGH SCHOOL,
Sullurpet.


Correspondent
TINY TOTS ENG. MED. HIGH SCHOOL
SULLURPETA, SPSR NELLORE DIST.

SPSR NELLORE (D) A.P. - 524 121

PRINCIPAL
TINY TOTS E.M. HIGH SCHOOL
Affiliation No.: 130503
Affiliated to CBSE - New Delhi
SULLURPET - 524 121,
SPSR NELLORE (Dt.) A.P.